

TOWN OF SOUTHWEST RANCHES
REQUEST FOR QUOTATIONS
"SPREADING SURPLUS FILL MATERIAL AT COUNTRY ESTATES PARK PLAY FIELD"
RFQ No.: 22-112

Questions for RFQ 22-112"Spreading Surplus Fill Material at Country Estates Park Play Field"

1. When is the earliest anticipated date that this project can start? And is there a deadline for the completion of the project?
As soon as possible for both questions.
2. Does the project require a signed and sealed survey by a professional surveyor after completion? **Not necessary.**
3. Spreading the fill will disturb all grassed areas within the highlighted purple box. Does the area need to be sodded or seeded after it has been graded? **Not necessary. The purpose of the project is to make the surface level and mowable. Further improvements will be done later.**
4. Does the perimeter of the work area need to have Silt fence installed? **Not necessary, so long as appropriate caution is used when spreading the fill to avoid placing it anywhere but on the field.**
5. Does the fill need to be pitched on any direction for drainage purposes? **Yes. The original design had very subtle "dome-like" grading. Essentially, the water should be running off from the center of the field to the perimeter. The exiting change in elevation is almost imperceptible.**